



Hot Work Permit

Date Work to Begin:	Date of Issue:	Date of Completion/Expiration:
Company Name:		
Foreman/Supervisor:	Emergency Contact Number:	
Phone Number:	Hours of Operation:	
Location of Site Where Work is to be Performed:	<input type="checkbox"/> Inside	<input type="checkbox"/> Outside
Description of Work to be Performed:		
Equipment to be Used:		
Electric Arc <input type="checkbox"/>	Acetylene Generator <input type="checkbox"/>	Other _____
Calcium Carbide <input type="checkbox"/>	Gas Cylinders	
Fire System Impairment Required?.....	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Cylinder Storage Required?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
<input type="checkbox"/> Inside	<input type="checkbox"/> Outside	
Welding/cutting operations shall be performed in accordance with the requirements established by OSHA, NFPA 51B Standards, and Company Standards		
Compliance with all requirements established in the documents listed above shall be the responsibility of all personnel performing welding/cutting operations.		
Emergency Phone Numbers:		
Inspection Date:	Inspection time:	
Safety Coordinator's (or designee's) Signature:	On-site Foreman's/Supervisor's Signature:	
Send copies to:		



REQUIRED PRECAUTIONS CHECKLIST

Fire Systems and Equipment

- Available sprinklers, hose streams and extinguishers are in service/operable.
- Hot Work equipment in good repair.

Requirements within 35 ft of work

- Flammable liquids, dust, lint and oily deposits removed.
- Explosive atmosphere in area eliminated.
- Floors swept clean.
- Combustible floors wet down, covered with damp sand or fire-resistive sheets.
- Remove other combustibles where possible. Otherwise protect with fire-resistive tarpaulins or metal shields
- All wall and floor openings covered.
- Fire-resistive tarpaulins suspended beneath work.

Work on walls or ceilings

- Construction is noncombustible and without combustible covering or insulation.
- Combustibles on other side of walls moved away.

Work on enclosed equipment

- Enclosed equipment cleaned of all combustibles.
- Containers purged of flammable liquids/vapors.

Fire watch/Hot Work area monitoring

- Fire watch will be provided during and for 60 minutes after work, including any coffee or lunch breaks
- Fire watch is supplied with suitable fire extinguishers.
- Fire watch is trained in use of this equipment and in sounding alarm.
- Fire watch may be required for adjoining areas, above, and below.
- Monitor Hot Work area for 4 hours after job is completed.

Other Precautions Taken